

CITY OF GALLUP
CENTRAL PURCHASING OFFICE
P.O. BOX 1270
GALLUP, NEW MEXICO 87305-1270
Phone: 505-863-1334; Fax: 505-722-5133

PARK PUMP STATION TO GRANDVIEW TANK 16" TRANSMISSION WATER MAIN

AMENDMENT NO.: One (1)
PAGES: # (3)

FORMAL BID NO.: 1717

THE FOLLOWING REVISIONS, ADDITIONS AND/OR CLARIFICATIONS SHALL FORM A PART OF THE CONTRACT DOCUMENTS AND EACH BIDDER SHALL INDICATE ON THEIR BID THE RECEIPT OF THIS NUMBERED AMENDMENT. REVISIONS, ADDITIONS, AND/OR CLARIFICATIONS ARE AS FOLLOWS:

This Amendment No. 1 Contains the Following:

- Responses to Inquiries received by the City of Gallup and DePauli Engineering & Surveying, LLC and Miscellaneous Clarifications (pages 1-3)

RESPONSES TO INQUIRIES RECEIVED BY THE CITY OF GALLUP AND DEPAULI ENGINEERING & SURVEYING, LLC AND MISCELLANEOUS CLARIFICATIONS

Pre-Approval of "OR EQUAL" Products

No determination will be given for products submitted for pre-approval or "as equal" to those called for prior to the award of the project.

Contractor Questions: (Questions are taken directly from contractor or supplier emails)

Q: I reviewed this project and noticed that you had a fence specification in this project. I reviewed the plans and bid documents and did not find any fencing on this project. Is there a scope of work for fence on this project and if so, what plan sheets does it appear on?

A: See sheet 2-4 upper right side of sheet. Note reads:

"REMOVE AND REPLACE CHAIN-LINK FENCE AS REQUIRED..."

New waterline passes through existing 16' wide gate. If fence removal is required, replacement shall meet included project fence specifications. In the event that removed existing fence is undamaged and meets project specifications, replacement with existing fencing is acceptable.

Required removal of existing fencing for installation of utility, and replacement with fencing meeting project specifications shall here by be considered incidental to this contract.

Q: Will American Made Material be required for this project?

A: No.

Q: *Plan Sheet 2-2, near Sta. 15+80 there is a Call Out for "REMOVE and REPLACE 36" CMP as Required." Will this be Reinstalling existing CMP or Supplying and Installing New CMP? If new CMP what Bid Item should this be in and what is the anticipated quantity to be provided?*

A: Refer to sheet 1-2 Partial list of incidentals: 21:

"UTILITIES THAT ARE DAMAGED OR CUT SHALL BE REPAIRED BY THE CONTRACTOR AT THEIR COST"

Existing drainage structures that are in reasonable usable condition may be reused.

Grading adjustments to maintain drainage with reasonably shorter drainage structure may be acceptable.

Q: *What is the anticipated date of Notice of Award?*

A: Unknown.

Q: *Is a soils report available?*

A: No.

Q: *For the areas of Jack and Bore: what is the psi of the existing soil?*

A: Unknown.

Q: *Bid Item 10, DI Fittings. Can you confirm the bid quantity? It appears low. Our takeoff has that quantity at approx. 6,000 lbs. Bid Item #6 and sheet SC-9 state that fittings are not to be included, therefore included in Bid Item 10.*

A: Estimate bid quantity for bid item 10 is appropriate.

Q: *Bid item 11; Rock Excavation. Is the rock Type A or Type B? Sheet SC-10 describes the Rock as both. Is there any way to clarify?*

A: No.

Q: *Sheet 2-1, STA 2+38 calls for Locking DIP until STA 6+42. Just to clarify: This quantity is separate from the quantity called out as carrier pipe in the bore areas.*

A: Bid items 1 and 2 are lump sum items which include internal locking DI carrier pipe. Bid item 4 is for the installation of internal locking DIP which is direct bury installed in accordance with ITEM 4 on page SC-8.

Q: *Related to above question #5. Just for clarification. Carrier pipe is locking 16" DIP and is included in Bid Item 1 and 2, and not counted as part of Bid Item 4.*

A: See above.

Q: *Sheet 2-2. Can you clarify the area to be re-seeded? Plans indicate 300 cy of grading, however the surface area is not clearly defined.*

A: Drawing is to scale with elevation contours. Re-seeding under this item is confined to the area affected by the contractor.

Q: Sheet 2-4. Can a bid item be added for Remove and Replace Fence?

A: No. See above questions and answers.

Q: Sheet 2-4. WL is at shown on P&P at approx. 8' cover. Key note 1 calls for WL to be installed at 4' cover from adjacent curb. Can you clarify? If WL is to installed at 8' cover, the asphalt patch at Kit Carson will need to increase size.

A: Drawing is to scale with elevation contours. Required minimum bury is with respect to adjacent curb elevation. Pipe line must maintain positive grade with respect to increase in stationing. Quantity of asphalt patch is an estimate.


END OF RESPONSES TO INQUIRIES RECEIVED BY THE CITY OF GALLUP AND DEPAULI ENGINEERING & SURVEYING, LLC AND MISCELLANEOUS CLARIFICATIONS

Bid opening time and date remain unchanged.

This amendment consists of 3 pages. If you do not receive all 3 pages, contact the City of Gallup Purchasing Office immediately.

City of Gallup:

DATE: January 23, 2018


BY/S/ Frances Rodriguez, CPPB
Frances Rodriguez, CPPB,
Purchasing Director

**Acknowledge
Receipt No. One (1)**

**Contractor:
BY/S/ _____
Authorized Signature of Seller/Bidder**

Company Name: _____

ACKNOWLEDGE RECEIPT ON BID OR SIGN AND RETURN ONE (1) COPY WITH BID!

BIDDERS LIST**CITY OF GALLUP, FORMAL BID NO. 1717****PARK PUMP STATION TO GRANDVIEW TANK 16" TRANSMISSION WATER MAIN****BID OPENING: 1/30/2018 AT 2:00 pm****ENGINEERS ESTIMATE: \$996,593 including tax****Page 1**

SET #	SENT TO	PHONE # FAX #	DATE	ADDENDUM No. 1	RETURNED
1	DePauli Engineering & Surveying Office Copy	Phone: (505) 863-5440 Fax: (505) 863-1919			
2	Frances Rodriguez City of Gallup	Phone: (505) 863-1334 Fax: (505) 722-5133	Delivered 12/29/2017		
3	Dennis Romero City of Gallup	Phone: (505)863-1289 Fax: (505) 726-1278	Delivered 12/29/2017		
4	Dodge Data & Analysis 4300 Beltway Place, Suite 180 Arlington, TX 76018-5253	Phone: (951) 547-4485 Fax: (800) 768-5594	USPS 12/29/2017		
5	Construction Reporter 1609 2nd St. NW Albuquerque, NM 87102	Phone: (505) 243-9793 Fax: (505) 242-4758	USPS 12/29/2017		
6	The Plan Room at Sun Glass 648 West Broadway Farmington, NM 87401	Phone: (505) 327-0700 Fax: (505) 324-9885	USPS 12/29/2017		
7	Dallago Corporation 2411 E. Aztec Ave Gallup, NM 87301	Phone: (505) 722-6638 Fax: (505) 863-9433	Pick up 1/2/2018		
8	NM Underground Utilities, Inc. 6201 Industry Way SE Albuquerque, NM 87105	Phone: (505) 877-2300 Fax: (505) 877-1272	FedEx 1/3/2018		
9	Murphy Builders 808 S. Boardman Gallup, NM 87301	Phone: (505) 863-6274 Fax: (505) 863-9442	Pick up 1/4/2018		
10	TLC Plumbing & Utility 5000 Edith Blvd NE Albuquerque, NM 87107	Phone: (505) 385-1067 Fax: (505) 761-5559	1/4/2018		
11	ConstructConnect (iSqFt) 30 Technology Parkway South, Ste 100 Norcross, GA 30092	Phone: (800) 364-2059 Fax: (866) 570-8187	FedEx 1/4/2018		
12	File Construction, LLC 119 Industrial Ave NE Albuquerque, NM 87107	Phone: (505) 554-1780 Fax: (505) 554-3195	FedEx 1/8/2018		

SET #	SENT TO	PHONE # FAX #	DATE	ADDENDUM No. 1	RETURNED
13	Adame Construction Inc. 13 Bonita Vista Blvd Los Lunas, NM 87031	Phone: (505) 573-0348 Fax: (505) adameconstnm@hotmail.es	Picked Up 1/12/2018		
14					
15					
16					
17					