

CITY OF GALLUP
CENTRAL PURCHASING OFFICE
P.O. BOX 1270
GALLUP, NEW MEXICO 87305-1270
Phone: 505-863-1232; Fax: 505-722-5133

**SANTA FE WELLS NO. 11 AND 12 MODIFICATIONS CONSTRUCTION CONTRACT NO. 1
FORMAL BID NO. 2019
CITY OF GALLUP**

AMENDMENT NO.: One (1)
PAGES: # (3)

FORMAL BID NO.: 2019

THE FOLLOWING REVISIONS, ADDITIONS AND/OR CLARIFICATIONS SHALL FORM A PART OF THE CONTRACT DOCUMENTS AND EACH BIDDER SHALL INDICATE ON THEIR BID THE RECEIPT OF THIS NUMBERED AMENDMENT. REVISIONS, ADDITIONS, AND/OR CLARIFICATIONS ARE AS FOLLOWS:

This Amendment No. 1 Contains the Following:

- Questions and Answers received by the City of Gallup and DePauli Engineering & Surveying, LLC (2 pages)
- Plan Holders List (1 page)

RESPONSES TO INQUIRIES RECEIVED BY THE CITY OF GALLUP AND DEPAULI ENGINEERING & SURVEYING AND MISCELLANEOUS CLARIFICATIONS

Contractor Questions: Questions are taken directly from contractor or supplier emails.

Questions for Gallup – Santa Fe Wells No. 11 and 12 Modifications Construction Contract No. 1:

1. *Spec 503.2.11 shows a pressure rating of 250 PSI, which may need to have Class F flange, Spec 17510, 2.01 B.1. shows metering tube with 150 lb. Class D flanged connection. Please specify the Class and rating of the Flange required.*

A: The language in Spec 503.2.11 “rated for a 250 psi pressure, and have flanged connections.” shall hereby be replaced with “and have 150 lb. class D flanged connections.”

2. *Will the Electrical Contractor on Contract No. 1 make the final above ground electrical connections of the drop power cable to the motor controller/starter under contract No. 1?*

A: Yes, the electrical contractor on Contract No. 1 will be on site for final above ground electrical connections and pump startup. This will require a designated trip for well start-up upon completion pump assembly installation as part of Contract No. 2. Coordination with Contract No. 2 Contractor is required.

No other questions have been received and future questions will not be answered.

Bid opening time and date remain unchanged.

This amendment consists of 3 pages. If you do not receive 3 pages, contact the City of Gallup Purchasing Office immediately.

City of Gallup:

DATE: **June 25, 2020**

Acknowledge
Receipt No. **One (1)**

BY/S/ 
Frances Rodriguez, CPPB,
Purchasing Director

Contractor:
BY/S/ _____
Authorized Signature of Seller/Bidder

Company Name: _____

[ACKNOWLEDGE RECEIPT ON BID OR SIGN AND RETURN ONE (1) COPY WITH BID]

PLAN HOLDERS LIST
CITY OF GALLUP, FORMAL BID NO. 2019
SANTA FE WELL NO. 11 & 12 MODIFICATION CONSTRUCTION CONTRACT NO. 1
BID OPENING: JUNE 30, 2020
ENGINEERS ESTIMATE: \$230,185.73

SET #	SENT TO	PHONE # FAX #	DATE	ADDENDUM No. 1	RETURNED
1	DePauli Engineering & Surveying Office Copy	Phone: (505) 863-5440 Fax: (505) 863-1919	In Office 5/29/2020		
2	Frances Rodriguez City of Gallup	Phone: (505) 863-1334 Fax: (505) 722-5133	Delivered 5/29/2020		
3	Dennis Romero City of Gallup	Phone: (505)863-1290	Delivered 6/1/2020		
4	Construction Reporter 4901 Mcleod Road NE, Suite 200A Albuquerque, NM 87109	Phone: (505) 243-9793 Fax: (505) 242-4758	USPS 6/1/2020		
5	Dodge Data & Analysis 4300 Beltway Place, Suite 150 Arlington, TX 76018	Phone: (817) 527-8246 Fax: (800) 768-5594	USPS 6/1/2020		
6	CMD 30 Technology Pkwy South, Ste. 100 Norcross, GA 30092	Phone: (800) 364-2059 Fax: (800) 303-8629 email: jacob.hughes@constructconnect.com	USPS 6/1/2020		
7	Smithco Construction, Inc. 6 King Canyon Loop Caballo, NM 87931	Phone: (575) 894-6161 Fax:	FedEx 6/1/2020		FedEx 6/4/2020
8	Stewart Brothers Drilling Company P.O. Box 2067 Milan, NM 87021	Phone: (505) 287-2986 Fax:	Picked Up 6/2/2020		
9		Phone: Fax:			
10		Phone: Fax:			
11		Phone: Fax:			